



# CAPE ENVIRONMENTAL LABORATORY, L.L.C.

102 North Main • Cape May Court House, NJ 08210

Phone: 609-463-0077

Fax: 609-463-8977

D.E.P. Cert. #05679

**CLIENT:** Mainland Regional High School  
**SCHOOL:** Mainland Regional High School  
**ADDRESS:** 131 Oak Avenue  
Linwood, NJ 08221-1698

**SAMPLE#:** 48906  
**SAMPLE DATE:** 5/10/16 6:40am-6:59am  
**SAMPLED BY:** CEL Tim Delp  
**RECEIVED:** 5/10/2016

<u>ID #</u>	<u>LOCATION</u>	<u>CLIENT ID</u>	<u>ANALYSIS TIME</u>	<u>Pb ug/L</u>	<u>MCL</u>
-1	W-01	1	5/12/2016 9:58am	<2.0	15ug/L
-2	End Hall Near Nurse	2	5/12/2016 9:58am	<2.0	15ug/L
-3	A- Hall Concession	3	5/12/2016 9:58am	<2.0	15ug/L
-4	Pool Lobby Left	4	5/12/2016 9:58am	<2.0	15ug/L
-5	Pool Lobby Right	5	5/12/2016 9:58am	<2.0	15ug/L
-6	Art Room Right	6	5/12/2016 9:58am	<2.0	15ug/L
-7	W-14	7	5/12/2016 9:58am	<2.0	15ug/L
-8	Science Wing 1	8	5/12/2016 9:58am	<2.0	15ug/L
-9	Science Wing 2	9	5/12/2016 9:58am	<2.0	15ug/L
-10	Science Wing 3	10	5/12/2016 9:58am	<2.0	15ug/L
-11	Assistant Principal	11	5/12/2016 9:58am	<2.0	15ug/L
-12	Child Study	12	5/12/2016 9:58am	<2.0	15ug/L
-13	Music Room	13	5/12/2016 9:58am	<2.0	15ug/L
-14	N 2	14	5/12/2016 9:58am	<2.0	15ug/L
-15	Cafeteria East	15	5/12/2016 9:58am	<2.0	15ug/L

To the best of our knowledge, all samples were first draw of the day.

Analysis Method SM 3113B

Timothy Delp, Laboratory Director